

Grooved Couplings or Fittings

Grooved couplings are used to join pipe and fittings in both wet and dry sprinkler systems. Unless otherwise noted, these couplings are intended to provide some flexibility in piping systems. Typical applications are in sprinkler risers, in feed mains passing through walls from one building area to another, in locations subject to earthquakes, in the discharge line from aboveground pump suction tanks, in new connections to existing feed mains and in air or water fire service lines subject to excessive vibration or difficult alignment.

Unless otherwise noted, these couplings are limited to use with rolled or cut groove-ended pipe, valves and fittings, at a minimum rated working pressure of 175 psi (1205 kPa) and are suitable for aboveground service. Higher rated pressures are noted in the text of the listing. Selection of pipe schedules for use with grooved pipe couplings should be made according to applicable FM Global Property Loss Prevention Data Sheets installation standards. These pipe schedules determine system pressure ratings and may take precedence over the higher rated working pressures listed for some couplings.

Installation must be made according to the manufacturer's instructions and requirements. Where couplings are used to join FM Approved pipe, the pipe manufacturer's installation instructions and requirements must also be observed. Grooves should be made according to ANSI/AWWA C606 (latest edition), "Grooved and Shouldered Joints", unless otherwise specified.

FM Approved grooved pipe couplings joining steel pipe may be used in underground service, subject to the installation restrictions placed upon the pipe and to the coupling manufacturer's recommendations and requirements.

Unless otherwise stated in the listing, these couplings have been evaluated for a maximum ambient temperature of 225°F (107°C), suitable for use in normal warehouse protection. For special applications, temperatures, or environments, the manufacturer's recommendations and requirements are to be followed.

Grooved Split Flanges-Flexible

Split Flanged-These fittings join pipe, valves or fittings having equal diameters.

XGQT5, XGQT5A

Product Designation	Nominal Pipe Size, mm	Bolt Pattern	Remarks	Max Working Pressure, psi (kPa)
XGQT5	60.3, 73.0, 76.1, 88.9, 108.0, 114.3, 133.0, 139.7, 141.3, 159.0, 165.1, 168.3, 219.1, 273.0, 323.9	ASME/ANSI B16.1 Class 125	a, b, c, d, e, f	300 (2070)
XGQT5A	60.3, 73.0, 76.1, 88.9, 108.0, 114.3, 133.0, 139.7, 141.3, 159.0, 165.1, 168.3, 219.1, 273.0, 323.9	ASME/ANSI B16.1 Class 125	a, b, c, d, e, f	300 (2070)

Remarks:

- Min schedule cut groove pipe to be joined: 6 in. or smaller - Schedule 40; 8 in. or larger - Schedule 30
- Min schedule rolled groove pipe to be joined: 6 in. or smaller - Schedule 40; 8 in. or larger - Schedule 30
- Minimum schedule rolled groove pipe to be joined: 6 inch or smaller, Schedule 10; 8 or 10 inch - 0.188 inch (5 mm) wall; 12 inch - 0.250 in. wall
- With Grade E EPDM gasket
- FM Approved for use with rolled groove GB/T3091-2008 steel sprinkler pipe with comparable wall thicknesses to Schedule 10 steel sprinkler pipe per ASME B36.10-2004 specifications.
- FM Approved for use with rolled or cut groove GB/T3091-2008 steel sprinkler pipe with comparable wall thicknesses to Schedule 40 steel sprinkler pipe per ASME B36.10-2004 specifications.

Company Name:	Shandong Dingliang Fire Technology Co Ltd
Company Address:	Cheliuzhuang Village Jiulong Sub-office, Fangzi District, Weifang 261200, China
Company Website:	http://www.ding-liang.com
New/Updated Product Listing:	No
Listing Country:	China
Certification Type:	FM Approved